

Updates on the Naramata Water System

November 12, 2014

Doug French, P.Eng.
RDOS Public Works Manager
250-490-4103

dfrench@rdos.bc.ca

Liisa Bloomfield, P.Eng.
RDOS Engineer
250-490-4229

Lbloomfield@rdos.bc.ca

Outline

- Recent system upgrades
- Capital plan and DCC update
- Future watermain replacements
- Flume replacement
- Standby power generators
- Reserve funds
- Next steps


Recent System Upgrades

Recent Upgrades

- On Arawana Road up to Juniper Road
 - Critical section of pumping main to upper reservoirs – Juniper, Arawana & Stonebrook
 - 2 separate projects
 - Pipe bursting from Arawana to Juniper Road
 - Replacements on Arawana, Spruce, Ponderosa, part of Debeck
- Hydrant Installations


Pipe Bursting Project

- Minimal excavation required
- Existing pipe used to pull through new pipe



Pipe Bursting Project


- Completed July '14
- Approx \$191k
- 280 m of new pipe



Juniper
Reservoir




2014/04/10



Arawana Watermain Project

- All watermain work complete this week
- Paving
 - Weather dependent
- Landscaping will be completed in 2015
- Added meter pits to all connections (total 37)



Hydrant Installations


- 5 locations selected to enhance coverage
- 4 completed:
 - Near 2275 Naramata Road
 - Near 2785 Gammon Road
 - Near 940 Salting Road
 - Corner of Gulch Road & Orchard Lane
- 1 remaining to be completed:
 - Corner of Clarke Road & Gulch Road
- Cost estimated at \$74k

Capital Plan & DCC Bylaw

Capital Plan Summary


- Infrastructure assessment complete
- Previously presented in 2013
- Summary of conclusions
 - Large amount of assets will need replacement by 2019:
Approx \$6 Million

Graph represents the deterioration of infrastructure over a 40 year lifespan



Expected Remaining Life

- Priorities will be watermains, water intake, pumpstations and pressure related valves



Capital Upgrades

- Pending - final report for upgrade priority
 - List will be guide for staff
 - Listed items may move up or down
- Next potential location
 - 150m along Juniper Drive to reservoir site
 - Hyde Road (several breaks)



Examples of
Asbestos
Cement pipe



DCC Update & Bylaw

- DCC (Development Cost Charge)
 - Monies collected from developers to offset cost to upgrade infrastructure to accommodate needs of new development
- Draft report under review
- DCC bylaw to be written in 2015
- Additional information and discussion coming in 2015

Flume Replacement

Flume Replacement

- Flume diverts water from Robinson Creek to Naramata Creek – 730m long
- Past requirement to maintain fish flow in Naramata Creek
- Investigating options for maintaining or decommissioning
- Upgrade cost estimated at \$300k

Flume




Standby Power

Standby Power Overview

- General system layout
- Why do we need it?
 - Evaluating fire risk
 - Storage requirements
 - Creek intakes
- Preliminary design
- Cost estimates

Generalized Layout of Water System




Why do we need it?

- Fire hazard risk
 - Interface zone
- Storage requirements

Existing Fire Risk

- Moderate, high & extreme hazard areas within or adjacent to Naramata
- Extreme hazard areas
 - located in upper area near Stonebrook and Arawana reservoirs
- 2006 Fire Underwriters Report
 - Recommended standby power be provided
 - 2007 upgrade project initially included but were removed due to inadequate budget

Fire Hazard Mapping



Water Availability

- Ensure water availability for fire suppression purposes
- Power frequently turned off in wildfire event
- Current water supply when power off
 - Storage in reservoirs
 - Standby gravity creek sources

Reservoir Storage

- Requirements based on
 - Land use
 - Balancing maximum demands
 - Fire suppression purposes
 - Emergency storage for allowing time for staff to respond to situations
- Stonebrook & Arawana reservoirs
 - Services about 20% of system demands
 - Sufficient capacity

Reservoir Storage

- McKay & Juniper reservoirs
 - Service about 80% of total system demands
 - Deficient in balancing, fire flow and emergency storage requirements
 - Rely on pumping infrastructure for peak demands and fire flows
 - During periods of high demand
 - Pumps operate continuously

Starting Creek Intakes

- Intake bypass gate closed
- Setting pond cleared of sediment and filled
- Set up chlorination system – Chlorine gas
- Begin filling transmission main & flush
- Introduce water to distribution system
- Naramata Dam adjusted - increase water
- To start one intake:
 - 4-6 hours for 2 operators

Creek Intake Sources

- Significant operational challenges
 - Boil water notice required
 - Chlorine cylinders brought in (restricted in fire)
 - Clean out sediment – need excavator onsite
 - Access to intakes restricted during fires
 - Creeks can carry fire retardants from fire zone
 - Extensive disinfection and flushing of system
 - Lower than Stonebrook reservoir

Creek Intake Sources

- Requirements for Continued Maintenance
 - Settling ponds
 - Cleaned out of accumulated sediment
 - Extensive concrete repairs
 - Upgrade some piping
 - Dosing meter for chlorine required at one site

Standby Power Design

- Completed Preliminary Design Report
 - Sizing requirements
 - Evaluate options
 - Siting considerations
 - Storage versus pumping requirements
 - Cost estimates
- Detailed Design 90% complete

Standby Power

- Three generators required - \$1.18 Million
 - Raw water pumpstation
 - \$506,000 (\$50k in extra sound dampening)
 - McKay treatment plant
 - \$506,000
 - Juniper reservoir & pumpstation
 - \$166,000
- Estimates include generators, electrical, instrumentation, and site work (excavation, fencing, retaining walls, etc)

Capital & Twinning Reserve Funds

Capital Reserves

- Created as a reserve bylaw
 - Bylaw No. 1788, 1997
- Included in the general water charge of \$802.64 per year (\$200.66 quarterly)
 - Capital reserve contribution estimated at \$262 per year per property (\$65.50 quarterly)
 - Typically \$250,000 per year contributed

Twinning Reserve

- Created as a reserve bylaw
 - Bylaw No. 2355, 2005
- \$131 per year (\$32.75 quarterly)
 - Total - \$125,000 per year
 - Typical residential: 10-12% of utility bill

Reserve Funds

- Estimated funds available at end of 2014:
 - Capital Reserve: \$ 830k
 - Twinning Reserve: \$1.35 Million
- Twinning Reserve
 - When reserve is no longer required it may be transferred into another reserve if:
 - Service area is the same
 - Properties are the same
 - Process – completed in another 6 months

Future of Twinning Reserve

- When reserve is no longer required it may be transferred into another reserve if:
 - Service area is the same
 - Properties are the same
- Process – in progress
 - Estimated completion in another 6 months

Next Steps

- Completion of capital upgrade plan
 - Prioritize for replacement
- DCC Bylaw development
- Transfer of Twinning Reserve to Capital Reserve & renamed on quarterly bills
- Generator installations ??

Questions??

- Please contact us anytime with questions

Doug French, P.Eng.

RDOS Public Works Manager

250-490-4103

dfrench@rdos.bc.ca

Liisa Bloomfield, P.Eng.

RDOS Engineer

250-490-4229

Lbloomfield@rdos.bc.ca



